Slim I/O Relay G2RV-SR/G3RV-SR

Global standard size, low profile slim I/O relay with width 6.2 mm, slim I/O solid state relay

- Realized about 25% lower profile than conventional products, contributing to further miniaturization of the control panel.
- Push-In Plus technology are used to save wiring work in comparison with conventional screw terminals.
 (Wiring time is reduced by 60%* in comparison with traditional screw terminals.)
- No screw loosening means maintenance-free application, realizing high reliability
- 'Hand-free' structure that holds an inserted flat-blade screwdriver to achieve easier wiring work for stranded wires.
- Screw terminal is also stocked to meet the screw type needs.
- Mounted relay or solid-state relay has a plug-in terminal that is difficult to bend at the time of exchange.
- Coil surge absorption circuit is equipped as standard.
- *According to OMRON actual measurement data from November 2015.





For the recent information on models that have been certified for safety standards, refer to your OMRON website.

Slim I/O Relay Types


G2RV-SR series mounted relay: electromagnetic relay from page 2
G3RV-SR series mounted relay: solid state relay from page 10


Common matter

Slim I/O Relay G2RV-SR

Global standard size, low profile slim I/O relay with width 6.2 mm


- Realized about 25% lower profile than conventional products, contributing to further miniaturization of the control panel.
- Realized opening and closing ability with one pole 6 A slim shape.
- Micro load products for one pole 50 mA using Au-plated contacts for small load switching also available.
- Since G2RV is a transparent case, confirming the state of the contact with the naked eye is possible, and easy to confirm abnormality on-site (installed location).
- Screw terminal is also stocked to meet the screw type needs.
- Mounted relay uses plug-in terminals that are difficult to bend when exchanging.
- G3RV-SR featuring a solid state relay similar in shape to G2RV-SR also available.
- · Coil surge absorption circuit is equipped as standard.





For the recent information on models that have been certified for safety standards, refer to your OMRON website.

Features



Model Number Structure

Model Number Legend

G2RV-SR □□ □ - □ (2) (3) (4) (5) (6)

(1) Basic model name G2RV: Slim I/O Relay

(3) Terminal (wire connection)

(2) Sub type SR: Slim relay + integrated low profile socket 50: Push-In Plus Terminal 70: Screw terminal

(4) Latching lever (test switch) 0: Without latching lever 1: With latching lever

(5) Contact structure Blank: Standard AP: Microloads

(6) Rated input voltage 12, 24 VDC 24, 48 VAC/DC 100, 110, 200, 230 VAC

Ordering Information

Terminal (Wire connection)	Classification	Latching lever (Test switch)	Rated input	t voltage (V)	Model
			DC	12	G2RV-SR500 DC12
			DC	24	G2RV-SR500 DC24
			A C / D C	24	G2RV-SR500 AC/DC24
		NI-	AC/DC	48	G2RV-SR500 AC/DC48
	Oter-de-id	No		100	G2RV-SR500 AC100
	Standard		AC	110	G2RV-SR500 AC110
			AC	200	G2RV-SR500 AC200
				230	G2RV-SR500 AC230
Push-In Plus		V	DC 24 G2 H	G2RV-SR501 DC24	
Terminal		Yes	AC/DC	24	G2RV-SR501 AC/DC24
			DO	12	G2RV-SR500-AP DC12
			DC	24	G2RV-SR500-AP DC24
			$AC/DC \qquad \frac{2^4}{48}$	24	G2RV-SR500-AP AC/DC24
	Missalssals	No	AC/DC	48	G2RV-SR500-AP AC/DC48
	Microloads		AC	100	G2RV-SR500-AP AC100
				110	G2RV-SR500-AP AC110
				200	G2RV-SR500-AP AC200
				230	G2RV-SR500-AP AC230
			DC	12	G2RV-SR700 DC12
				24	G2RV-SR700 DC24
			AC/DC	24	G2RV-SR700 AC/DC24
		NI-		48	G2RV-SR700 AC/DC48
	Ot and and	No		100	G2RV-SR700 AC100
	Standard		40	110	G2RV-SR700 AC110
			AC	200	G2RV-SR700 AC200
				230	G2RV-SR700 AC230
Corous torminal		Voc	DC	24	G2RV-SR701 DC24
Screw terminal		Yes	AC/DC	24	G2RV-SR701 AC/DC24
			DC	12	G2RV-SR700-AP DC12
			DC	24	G2RV-SR700-AP DC24
			AC/DC	24	G2RV-SR700-AP AC/DC24
	Migrales	No	AC/DC	48	G2RV-SR700-AP AC/DC48
	Microloads	No		100	G2RV-SR700-AP AC100
			40	110	G2RV-SR700-AP AC110
			AC	200	G2RV-SR700-AP AC200
				230	G2RV-SR700-AP AC230

Note: Sockets are not sold individually.

Relay for Maintenance

Model Number Legend

 $\mathbf{G2RV} \underline{\mathbf{1}} - \underline{\mathbf{S}} \underline{\square} - \underline{\square} - \underline{\mathbf{G}} \underline{\square}$

(1) No. of poles

1: 1 pole

(2) Terminal S: plug-in

(3) Latching lever (Test switch)

Blank: Without latching lever I: With latching lever

(4) Contact material

Blank: Ag alloy

AP: Ag alloy + Au plating

(5) Types of relay for exchange G: G2RV-SR series equipped

Relay

(6) Rated coil voltage

Number: 11, 21, 48 VDC



G2RV-1-SI-G

G2RV-1-S(-AP)-G



List of Models

Туре	Latching Lever (Test switch)		Rated coil Model voltage (V)		Applicable model
			11	G2RV-1-S-G DC11	G2RV-SR700/500 DC12V
			21	G2RV-1-S-G DC21	G2RV-SR700/500 DC24V
			21	G2RV-1-3-G DC21	G2RV-SR700/500 AC/DC24V
	No	DC			G2RV-SR700/500 AC/DC48V
Standard	NO	DC			G2RV-SR700/500 AC100V
Standard			48	G2RV-1-S-G DC48	G2RV-SR700/500 AC110V
					G2RV-SR700/500 AC200V
					G2RV-SR700/500 AC230V
	Vaa	DC	21	C2DV 4 CL C DC24	G2RV-SR701/501 DC24V
	Yes	DC	21	G2RV-1-SI-G DC21	G2RV-SR701/501 AC/DC24V
			11	G2RV-1-S-AP-G DC11	G2RV-SR700/500-AP DC12V
			0.4	0000/4 0 40 0 0004	G2RV-SR700/500-AP DC24V
			21	G2RV-1-S-AP-G DC21	G2RV-SR700/500-AP AC/DC24V
Minnelped	N.	D.O.			G2RV-SR700/500-AP AC/DC48V
Microload	No	DC			G2RV-SR700/500-AP AC100V
			48	G2RV-1-S-AP-G DC48	G2RV-SR700/500-AP AC110V
					G2RV-SR700/500-AP AC200V
					G2RV-SR700/500-AP AC230V

Note: Voltage is reduced within the socket for the slim I/O relay, so the rated input voltage and rated coil voltage of replacement relays are different.

Accessories (order separately)

Refer to page 26 for G2RV-SR/G3RV-SR Common Accessories.

Specifications

Ratings

Coil ratings

Rated input		Rated curre	ent	Must operate voltage	Must release voltage	Power co	Power consumption Maximum allowable volta	
voltage	4	AC	DC	Percentage of the rated voltage		AC (VA)	DC (mW)	Percentage of the
	50 Hz	60 Hz	D 0			AO (VA)	BO (IIIIV)	rated voltage
12 VDC	-	_	27.9 mA			_	Approx. 300 mW	
24 VDC	-	_	13.5 mA		-	_	Approx. 300 mW	
24 VAC/VDC	12.5 mA	12.6 mA	12.6 mA			Approx. 0.5 VA	Approx. 300 mW	
48 VAC/VDC	5.9 mA	6.1 mA	5.2 mA	80% max.*	.0% max.* 10% min.	Approx. 0.4 VA	Approx. 250 mW	110%
100 VAC	5.9 mA	6.0 mA	_	00 /0 IIIax.	10 /6 111111.	Approx. 0.8 VA	_	11076
110 VAC	5.9 mA	5.9 mA	-			Approx. 0.8 VA	_	
200 VAC	6.6 mA	7.6 mA	-			Approx. 1.7 VA	_	
230 VAC	7.3 mA	8.4 mA	-			Approx. 1.7 VA	_	

Note: The operating characteristics are measured at ambient temperature of 23°C.

Contact ratings

Item	Standard (G2F	RV-SR700, 500, 701, 501)	For microloads (G2RV-SR700-AP, 500-AP) *2	
Contact configuration	SPDT			
Load	Resistive load (cosφ=1)	Inductive load (cos¢=0.4, L/R=7ms)	Resistive load (cosφ=1)	
Rated load	6 A at 250 VAC 6 A at 30 VDC	2.5 A at 250 VAC 2 A at 30 VDC	50 mA at 30 VAC 50 mA at 36 VDC	
Rated carry current	6 A		50 mA	
Maximum switching voltage	440 VAC, 125 VDC		30 VAC, 36 VDC	
Maximum switching current	6 A		50 mA	
Maximum switching power	1,500 VA 180 W	500 VA 60 W	-	
Failure rate P value (reference value) *1	10 mA at 5 VDC		1 mA at 100 mVDC	

^{*1.} P level: λ₆₀=0.1×10⁻⁶/times

Characteristics

Item		Standard (G2RV-SR700, 500, 701, 501)	For microloads (G2RV-SR700-AP, 500-AP)			
Contact resistance	*1	100 m Ω max.				
Operate (Set) time	*1	20 ms max.				
Release time *1		AC, AC/DC: 40 ms max. DC: 20 ms max.				
Maximum operating	g frequency	Mechanical: 18,000 operations/h Electrical: 1,800 operations/h (rated load)				
Insulation resistant	ce	1,000 MΩ min. (at 500 VDC)				
Dielectric strength		Between coil and contacts: 4,000VAC 50/60 Hz 1 min Contact between the same polarity: 1,000 VAC 50/60 Hz 1 min				
Vibration resistanc	e *2	Destruction: 10 to 55 to 10 Hz, single amplitude 0.50 mm (double amplitude 1.0 mm) Malfunction: 10 to 55 to 10 Hz, single amplitude 0.50 mm (double amplitude 1.0 mm)				
Shock resistance *:	2	Destruction: 1,000 m/s ² Malfunction: Energized 200m/s ² , Non-energized 100m/s ²				
	Mechanical	5,000,000 operations min.				
Endurance *1	Electrical	NO contact: 70,000 operations min. NC contact: 50,000 operations min. 5,000,000 operations min.				
Ambient operating	temperature	Operating: –40 to +55°C (with no icing or condensation)				
Ambient operating humidity		Operating: 5 to 85% RH				
Weight		Approx. 30 g				
Contact material		Ag alloy + Au plating				
Note: Above velues of	!::!!:=! !	<u> </u>	<u>l</u>			

Note: Above values are initial values.

^{*}Operating voltage will be, for mounting in the upside down direction, 85% max. (Upside down: Direction in which the mechanical indicator faces down)

This value is the value in switching frequency 120 operations/min.

*2. If the Au plating layer is destroyed, the number will be the same as the standard type.

^{*1.} Value is at ambient temperature of 23°C.


^{*2.} Value when the end plate is used.

Approved standards

UL (File No.E41643)

Model	Contact form	Operation coil ratings	Contact ratings	Operations
G2RV-SR series	SPDT	12 to 48 VDC 24 to 230 VAC	6 A at 250 VAC (Resistive load) 6 A at 30 VDC (Resistive load) 2 A at 400 VAC (Resistive load)*	6,000


^{*} If the load voltage exceeds 250 VAC, please attach with a spacing of 12 mm min., or use a separate plate (XW5Z-EP12).



TÜV (File No.R50327609, EN 61810-1)

Model	Contact form	Operation coil ratings	Contact ratings	Operations
G2RV-SR series	SPDT	12, 24 VDC 24, 48 VAC/VDC 100, 110, 200, 230 VAC	6 A at 250 VAC (Resistive load) 6 A at 30 VDC (Resistive load) 2 A at 400 VAC (Resistive load)*	50,000 50,000 6,000

^{*} If the load voltage exceeds 250 VAC, please attach with a spacing of 12 mm min., or use a separate plate (XW5Z-EP12).




Lloyd's (File No.07/10020)


Model	Contact form	Operation coil ratings	Contact ratings
			6 A at 250 VAC (Resistive load)
G2RV-SR500	SPDT	12, 24 VDC	2.5 A at 250 VAC (PF0.4)
G2RV-SR700	3701	24, 48 VAC/VDC 100, 110, 200, 230 VAC	6 A at 30 VAC (Ress)
			2 A at 30 VDC (L/R=7ms)
	SPDT		6 A at 250 VAC (Resistive load)
G2RV-SR501		12, 24 VDC	2.5 A at 250 VAC (PF0.4)
G2RV-SR701		24 VAC/VDC	6 A at 30 VAC (Ress)
			2 A at 30 VDC (L/R=7ms)
G2RV-SR500-AP G2RV-SR700-AP	SPDT	12, 24 VDC 24, 48 VAC/VDC 100, 110, 200, 230 VAC	0.05 A at 30 VAC (Resistive load) 0.05 A at 36 VDC (Resistive load)

Engineering Data

Endurance curve (N.O. side)





Switching capacity of DC resistive load



Dimensions (unit: mm)


Slim I/O Relay + socket Push-In Plus Terminal Block






Screw terminal

Models without latching lever (without test switch) G2RV-SR700 G2RV-SR700-AP



Terminal Arrangement/Internal Connection Diagram (TOP VIEW)

12 VDC




Note: For recommended ferrules, crimp tools, and types and gauges of wires, refer to 3. Recommended Ferrules and Crimp Tools on page 23.

Models with latching lever (with test switch) G2RV-SR701

77.5 35.18 (5.05)18.71 78.77 35.3 18.71

Terminal Arrangement/Internal Connection Diagram (TOP VIEW)

(11)





Note: For recommended ferrules, crimp tools, and types and gauges of wires, refer to 3. Recommended Ferrules and Crimp Tools on page 23.


35.18 51 65 56.2

Relay for maintenance

Models without latching lever G2RV-1-S-G G2RV-1-S-AP-G








Terminal Arrangement/ Internal Connection Diagram (TOP VIEW)


(Input circuit)



Models with latching lever (test switch) G2RV-1-SI-G







Terminal Arrangement/ Internal Connection Diagram (TOP VIEW)

(Input circuit)



Slim I/O Solid State Relay G3RV-SR

Global standard size, low profile type slim I/O solid state relay with width 6.2 mm.

- Realized about 25% lower profile than conventional products, contributing to further miniaturization of the control panel.
- Optimal slim, high frequency, high-speed opening and closing SSR (solid state relay).
- Realized a slim shape with a switching capacity up to 3 A (DC), and 2 A (AC).

Refer to Safety Precautions on page 20.


- Because MOSFET is used for the outlet element for the DC load, opening and closing load of 100 μA to 3 A is possible.
- Check operating status at a glance at the operating display LED.
- Mounted I/O SSR (solid-state relay) uses plug-in terminals that are difficult to bend when exchanging.
- G2RV-SR featuring a general-purpose relay similar in shape to G3RV-SR also available.



For the recent information on models that have been certified for safety standards, refer to your OMRON website.

Λ

Features



Model Number Structure

Model Number Legend

 $\frac{\mathbf{G3RV}\text{-}\mathbf{SR}}{(1)} \stackrel{\square}{(2)} \stackrel{\square}{(3)} \stackrel{-}{(4)} \stackrel{\square}{(5)}$

(1) Basic model name

G3RV: Slim I/O Solid State Relay

(2) Sub type

SR: Slim solid relay + integrated low profile socket

(3) Terminal (wire connection)

500: Push-In Plus Terminal 700: Screw terminal

(4) Output voltage specification

A : AC output (triac) zero cross function available AL : AC output (triac) zero cross function not available

D : DC output (MOS FET)

(5) Rated voltage input

12, 24 VDC 24, 48 VAC/VDC 100, 110, 200, 230 VAC

Ordering Information

Terminal (wire connection)	Applicable output load	Zero cross function		ut voltage /)	Model
			DC	12	G3RV-SR500-D DC12
			DC	24	G3RV-SR500-D DC24
			4.0/D0	24	G3RV-SR500-D AC/DC24
	DOLLAR		AC/DC	48	G3RV-SR500-D AC/DC48
	DC load	_		100	G3RV-SR500-D AC100
				110	G3RV-SR500-D AC110
			AC	200	G3RV-SR500-D AC200
				230	G3RV-SR500-D AC230
				12	G3RV-SR500-A DC12
			DC	24	G3RV-SR500-A DC24
				24	G3RV-SR500-A AC/DC24
			AC/DC	48	G3RV-SR500-A AC/DC48
Push-In Plus Terminal		Yes		100	G3RV-SR500-A AC100
			100	G3RV-SR500-A AC110	
			AC	200	G3RV-SR500-A AC200
				230	G3RV-SR500-A AC230
	AC load			12	G3RV-SR500-AL DC12
			DC	24	G3RV-SR500-AL DC24
				24	G3RV-SR500-AL AC/DC24
			AC/DC	48	G3RV-SR500-AL AC/DC48
		No		100	G3RV-SR500-AL AC/DC46
			AC		
				110	G3RV-SR500-AL AC110
				200	G3RV-SR500-AL AC200
			DC	230	G3RV-SR500-AL AC230
				12	G3RV-SR700-D DC12
				24	G3RV-SR700-D DC24
			AC/DC	24	G3RV-SR700-D AC/DC24
	DC load	_		48	G3RV-SR700-D AC/DC48
				100	G3RV-SR700-D AC100
			AC	110	G3RV-SR700-D AC110
				200	G3RV-SR700-D AC200
				230	G3RV-SR700-D AC230
			DC	12	G3RV-SR700-A DC12
			DC	24	G3RV-SR700-A DC24
			AC/DC	24	G3RV-SR700-A AC/DC24
Name and the second sec		V	AC/DC	48	G3RV-SR700-A AC/DC48
Screw terminal		Yes		100	G3RV-SR700-A AC100
				110	G3RV-SR700-A AC110
			AC	200	G3RV-SR700-A AC200
				230	G3RV-SR700-A AC230
	AC load			12	G3RV-SR700-AL DC12
			DC	24	G3RV-SR700-AL DC24
				24	G3RV-SR700-AL AC/DC24
			AC/DC	48	G3RV-SR700-AL AC/DC48
		No		100	G3RV-SR700-AL AC100
				110	G3RV-SR700-AL AC110
			AC	200	G3RV-SR700-AL AC200
	old individually.			230	G3RV-SR700-AL AC230

Solid state relay for maintenance

Model Number Legend

G3RV-□ □ **S** □ (1) (2) (3) (4)

(1) Output voltage specification

(3) Terminal S: Plug-in type

D: DC output

2: AC output

(4) Zero cross functions

Blank: Zero cross function available L: Zero cross function not available

(2) Rated current 02: AC output 2 A 03: DC output 3 A

(5) Rated input voltage Number: 12, 24, 48 VDC



List of Models

Insulation method	Operation Display	Output (SSR)	Zero cross Function	Rated output Load *	Rated input voltage (socket)	Model	Applicable model
					12 VDC	G3RV-202S DC12	G3RV-SR700/500-A DC12V
					24 VDC	G3RV-202S DC24	G3RV-SR700/500-A DC24V
					24 VAC/VDC	G3RV-2025 DC24	G3RV-SR700/500-A AC/DC24V
			Yes		48 VAC/VDC		G3RV-SR700/500-A AC/DC48V
			res		100 VAC		G3RV-SR700/500-A AC100V
					110 VAC	G3RV-202S DC48	G3RV-SR700/500-A AC110V
				2 A	200 VAC		G3RV-SR700/500-A AC200V
Photo-		AC		2 A (at 100 to	230 VAC		G3RV-SR700/500-A AC230V
triac		AC		240 VAC)	12 VDC	G3RV-202SL DC12	G3RV-SR700/500-AL DC12V
	Yes (green)		No		24 VDC	G3RV-202SL DC24	G3RV-SR700/500-AL DC24V
					24 VAC/VDC	G3RV-2025L DC24	G3RV-SR700/500-AL AC/DC24V
					48 VAC/VDC		G3RV-SR700/500-AL AC/DC48V
					100 VAC	G3RV-202SL DC48	G3RV-SR700/500-AL AC100V
					110 VAC		G3RV-SR700/500-AL AC110V
					200 VAC		G3RV-SR700/500-AL AC200V
					230 VAC		G3RV-SR700/500-AL AC230V
					12 VDC	G3RV-D03SL DC12	G3RV-SR700/500-D DC12V
					24 VDC	G3RV-D03SL DC24	G3RV-SR700/500-D DC24V
					24 VAC/VDC	G3RV-D033L DC24	G3RV-SR700/500-D AC/DC24V
Photo- voltage		DC		3 A (at 5 to	48 VAC/VDC		G3RV-SR700/500-D AC/DC48V
coupler		DC	_	(at 5 to 24 VDC)	100 VAC		G3RV-SR700/500-D AC100V
•				,	110 VAC	G3RV-D03SL DC48	G3RV-SR700/500-D AC110V
					200 VAC		G3RV-SR700/500-D AC200V
					230 VAC		G3RV-SR700/500-D AC230V

^{*} Different depending on the ambient temperature.

For more details, refer to Load current vs. ambient rated temperature on page 16.

Accessories (order separately)

Refer to page 26 for G2RV-SR/G3RV-SR Common Accessories.

Specifications

Rating (ambient temperature 25°C)

Input G3RV-SR700/500-A series

		F	Rated current				Input voltage
	Rated input voltage	AC		DC	Must operate voltage	Must release voltage	Percentage of the
	.	50 Hz	60 Hz		3 11 3		rated voltage
	12 VDC	_	_	15.0 mA	10.8 V max.		
	24 VDC	_	_	12.0 mA	21.6 V max.		±10%
	24 VAC/VDC	11.3 mA	11.4 mA	11.0 mA	21.6 V max.		
l	48 VAC/VDC	6.8 mA	6.9 mA	6.0 mA	43.2 V max.	1 V min.	
	100 VAC	6.2 mA	6.2 mA	-	90 V max.	I V IIIIII.	
	110 VAC	6.2 mA	6.2 mA	-	99 V max.		
	200 VAC	6.7 mA	7.9 mA	_	180 V max.		
	230 VAC	7.5 mA	8.8 mA	_	207 V max.		

G3RV-SR700/500-AL series

	F	Rated curre	ent			Input voltage
Rated input voltage	A	AC		Must operate voltage	Must release voltage	Percentage of the
3 .	50 Hz	60 Hz	DC	3 11 3		rated voltage
12 VDC	_	_	15.0 mA	10.8 V max.		
24 VDC	_	_	12.0 mA	21.6 V max.		±10%
24 VAC/VDC	11.4 mA	11.5 mA	11.0 mA	21.6 V max.		
48 VAC/VDC	7.7 mA	7.7 mA	6.9 mA	43.2 V max.	1 V min.	
100 VAC	7.3 mA	7.3 mA	-	90 V max.	I V IIIIII.	
110 VAC	7.3 mA	7.3 mA	-	99 V max.		
200 VAC	7.0 mA	8.1 mA	-	180 V max.		
230 VAC	7.7 mA	8.9 mA	_	207 V max.		

G3RV-SR700/500-D series

	Rated current					Input voltage
Rated input voltage	Rated input AC		DC	Must operate voltage	Must release voltage	Percentage of the
3 .	50 Hz	60 Hz		, onlinge		rated voltage
12 VDC	-	_	8.0 mA	10.8 V max.		
24 VDC	-	_	4.6 mA	21.6 V max.		
24 VAC/VDC	5.0 mA	5.1 mA	4.3 mA	21.6 V max.		
48 VAC/VDC	6.8 mA	6.9 mA	6.0 mA	43.2 V max.	1 V min.	±10%
100 VAC	6.2 mA	6.2 mA	_	90 V max.	- I V IIIIII.	1070
110 VAC	6.2 mA	6.2 mA	-	99 V max.		
200 VAC	6.7 mA	7.9 mA	-	180 V max.	=	
230 VAC	7.5 mA	8.8 mA	_	207 V max.		

Output

Item	G3RV-SR700/500-A(L)	G3RV-SR700/500-D	
Rated load voltage	100 to 240 VAC (50/60 Hz)	5 to 24 VDC	
Load voltage range	75 to 264 VAC (50/60 Hz)	3 to 26.4 VDC	
Load current	0.1 to 2 A (Ambient temperature=25°C)	100 μA to 3 A (Ambient temperature=25°C)	
Inrush current resistance	30 A (10 ms)	30 A (10 ms)	
Permissible l²t; Joule integral value (reference value)	15A ² s	9 A ² s	
Applied load capacity	400 W (Output voltage: 200 VAC)	72 W (Output voltage: 24 VDC)	

Characteristics

Item	G3RV-SR700/500-A	G3RV-SR700/500-AL	G3RV-SR700/500-D	
Operate time	1/2 cycle of load power supply +1 ms max.	3 ms max.	6 ms max.	
Release time	60 ms max.	60 ms max.	60 ms max.	
Output ON voltage drop	1.6 V (RMS) max.		_	
Output ON resistance		-	0.3 Ω max. (at 24 VDC)	
Leaked current	5 mA max. (at 200 VAC, 50/60 Hz))	10 μA max. (at 24 VDC)	
Insulation resistance	100 MΩ min. (at 500 VDC)			
Dielectric strength	Between input and output 2,500 V	AC 50/60 Hz 1 min		
Vibration resistance *	Malfunction: 10 to 55 to 10 Hz dou	ble amplitude 0.70 mm		
Shock resistance *	300m/s ²			
Ambient operating temperature	Storage: –30 to +100°C (with no icing or no condensation) Operating: –30 to +55°C (with no icing or no condensation)			
Ambient operating humidity	45 to 85% RH			
Weight	Approx. 38 g			
Pollution degree	2			
The degree of protection by IEC60529	IP20			
Rated impulse dielectric strength	4.0 kV/III			
Load category	LC-A DC-12			
Overload current profile	1.5le 1.1Ue 5s ON, 10s OFF, 10 cycles			
Rated insulation voltage	240 V			

^{*} Value when the end plate is used.

Approved standards

UL (File No.E64562)

Model	Input ratings	Contact ratings
G3RV-SR700/500-D series	12, 24 VDC 24, 48 VAC/VDC 100, 110, 200, 230 VAC	24 VDC 3 A (resistive load) at 25°C
G3RV-SR700/500-A(L) series	12, 24 VDC 24, 48 VAC/DC 100, 110, 200, 230 VAC	240 VAC 2 A (resistive load) at 25°C


TÜV (EN 62314)

Model	Input ratings	Contact ratings
G3RV-SR700/500-D series	12, 24 VDC 24, 48 VAC/VDC 100, 110, 200, 230 VAC	24 VDC 3 A (resistive load)
G3RV-SR700/500-A(L) series	12, 24 VDC 24, 48 VAC/VDC 100, 110, 200, 230 VAC	240 VAC 2 A (resistive load)


Engineering Data

Load current vs. ambient rated temperature G3RV-SR700/500-A(L) series

Product mounting spacing 10 mm (Separate Mounting)




Close mounting (up to 5 units *)




G3RV-SR700/500-D series

Product mounting spacing 10 mm (Separate Mounting)



Close mounting (up to 5 units *)




*When five or more are installed, install with 10 mm space between

For details, please refer to Mounting on page 25.


Inrush Current Resistance: Non-repetitive

Keep the inrush current to below the inrush current resistance value (i.e., below the broken line) if it occurs repetitively.

G3RV-SR700/500-A(L) series




G3RV-SR700/500-D series




Dimensions (unit: mm)

Solid state relay + socket Push-In Plus Terminal Block G3RV-SR500




Terminal Arrangement/ Internal Connection Diagram (TOP VIEW)


12 VDC



24 VDC




Other voltage




: Diode bridge

Note: For recommended ferrules, crimp tools, and types and gauges of wires, refer to 3. Recommended Ferrules and Crimp Tools on page 23.


Screw terminal G3RV-SR700






Terminal Arrangement/ Internal Connection Diagram (TOP VIEW)


12 VDC



24 VDC



Other voltage




: Diode bridge

Note: For recommended ferrules, crimp tools, and types and gauges of wires, refer to 3. Recommended Ferrules and Crimp Tools on page 23.

Solid state relay for maintenance


G3RV-D03SL G3RV-202S(L)






Terminal Arrangement/ Internal Connection Diagram (TOP VIEW)

G3RV-D03SL (input circuit)



Note: The load can be connected to either the positive or negative terminals.

G3RV-202S(L) (input circuit)




G2RV-SR/G3RV-SR

Safety Precautions

Be sure to read the *Safety Precautions for All Relays* in the website at the following URL: http://www.ia.omron.com/.

Format of Warning Indications



Meaning of Graphic Symbols for Ensuring Product Safety



Indicates the possibility of electric shock under specific conditions.



Used for general CAUTION, WARNING, or DANGER precautions for which there is no specified symbol. (This symbol is also used as the alerting symbol, but shall not be used in this meaning on the product.)



Indicates the possibility of explosion or rupture under specific conditions.



Indicates the possibility of injuries by high temperature under specific conditions.

∕!\ WARNING

Ensure that the socket is not charged during wiring and maintenance. Not doing so may result in electric shock.



Do not touch the terminal section of the G2RV-SR or the surrounding area while the power is being supplied. Doing so may result in electric shock.



♠ CAUTION

Minor electrical shock may occasionally occur. Do not touch the G3RV terminal section (i.e., current carrying parts) while the power is being supplied.



The G3RV may rupture if short-circuit current flows. As protection against accidents due to short-circuiting, be sure to install protective devices, such as fuses and no-fuse breakers, on the power supply side.



Minor electrical shock may occasionally occur.

Do not touch the main circuit terminals on the G3RV immediately after the power supply has been turned OFF.



Shock may result due to the electrical charge stored in the built-in snubber circuit.

Note: G3RV-202S(L), G3RV-SR500/700-A(L) series

Note: G3RV-202S(L), G3RV-SR500/700-A(L) series models only

Minor burns may occasionally occur.

Do not touch the G3RV or the heat sink while the power is being supplied or immediately after the power supply has been turned OFF.

The G3RV becomes extremely hot.



Provide a space of at least 3 mm between the G2RV-SR and ground. Not doing so may result in a ground fault.



Precautions for Safe Use

Transport

- Do not use the product if it has been dropped on the ground.
 Dropping the product may adversely affect performance.
- Do not drop the product or subject it to abnormal vibration or shock during transportation or mounting. Doing so may result in deterioration of performance, malfunction, or failure.
- Do not transport the product without it being packaged. Doing so may result in damage, malfunction, or failure.
- Do not transport the G3RV under the following conditions. Doing so may result in damage, malfunction, or deterioration of performance characteristics.
 - · High temperature, high humidity conditions
 - Conditions such as temperature change that causes rapid condensation
 - · Condition where it is not packaged

Operating and Storage Environments


- Do not use or store the product in the following locations. Doing so may result in damage, malfunction, or deterioration of performance characteristics.
 - Do not store in locations subject to ambient storage temperatures outside the range –40 to 70°C (for G2RV) and outside the range –30 to 100°C (for G3RV).
 - Locations subject to relative humidity outside the range 5% to 85% (for G2RV) and outside the range 45% to 85% (for G3RV).
 - · Locations subject to high temperature or high humidity.
 - Conditions such as temperature change that causes rapid condensation
 - · Locations where corrosive gases or flammable gases are present
 - · Location where rainwater or water droplets gets splashed
 - · Location with splashes of water, oil, and chemicals, etc.
 - · Locations with much dust, salt, and iron powder
 - · Location with blockers
 - Where static electricity or noise occurs
 - · Where strong electromagnetic field is generated
 - · Where there is a risk of exposure to radioactivity
- Do not use or store Sockets in environments that contain silicone gas, sulfidizing gas (e.g., SO₂ or H₂S), or organic gas, or near materials that contain silicone. Doing so may cause the contacts to be unstable or to fail.


Handling <G3RV>

Keep the G3RV well ventilated.
 There is a risk of short-circuiting or burning due to G3RV overheating.

Mounting

- Before you start wiring, please make sure that the socket is securely attached to the mounting rail. If the socket is unstable, it may come loose and risk of injury towards the workers.
- Please insert the flat-blade screwdriver to the bottom of the hole. If you do not insert the flat-blade screwdriver correctly, the cable will not be connected correctly.
- When lubricant such as oil is attached to the tip of the driver, the driver will fall off, with a risk of injury towards the workers.
- Do not tilt the G2RV-SR/G3RV-SR after mounting to the support rail. Doing so may apply excessive force to the mounting portion, possibly damaging the product. Attach end plates (PFP-M) to sandwich the product and hold it in place.





Usage

- Please select the load within the rated range. Doing so may result in damage, malfunction, or failure.
- Please use the power of the rated frequency. It may cause malfunction, failure, or risk of burnout.

<G3RV>

- Install G3RV according to instructions Mounting on page 25. If you
 install in the wrong direction, abnormal heat is generated, and may
 lead to short-circuiting or burning the output element.
- G3RV is an SSR that generates heat. Please observe the ambient temperature setting range of G3RV. If installing in an enclosed space, set a fan, and ventilate.
- When mounting G3RV to DIN rail, firmly fits into the groove. If it is not properly installed, there is a risk of it falling.

Wiring

- For the current to be applied, make sure a wire size with margin is used.
 Otherwise, excessive heat generated by the wires may cause burning.
- Do not attempt to use the wire if the coat is torn. Not doing so may result in electric shock.
- Always turn OFF the power supply before performing wiring. Not doing so may cause electrical shock.

<G3RV>

 The wires of the socket for G3RV socket should not be passed through the same duct as that being connected to the high-voltage power supply. Otherwise, inductive noise may damage the G3RV or cause it to malfunction.

Push-In Plus Terminal Block

- Do not wire anything to the release holes.
- Do not tilt or twist a flat-blade screwdriver while it is inserted into a release hole on the terminal block. The terminal block may be damaged.
- Insert a flat-blade screwdriver into the release holes at an angle.
 The terminal block may be damaged if you insert the screwdriver straight in
- Do not allow the flat-blade screwdriver to fall out while it is inserted into a release hole.
- Do not bend the wire past its natural bending radius or pull on it with excessive force. Doing so may cause the wire disconnection.
- Do not insert more than one wire into each terminal (insertion) hole.
- To prevent wiring materials from smoking or ignition, confirm wire ratings and use the wiring materials given in the following table.


Recommended Wire (UL and TÜV standard certification)	Stripping length (Ferrules not used)
0.5 to 1.5 mm²/ AWG20 to AWG16 stranded wire, 0.8 to 1.3 mm²/AWG18 to AWG16 solid wire	8 mm


Disposal


• When disposing of the product, do not put into the fire.

Precautions for Correct Use


- Do not use or store the product in the following locations. Doing so may result in damage, malfunction, or deterioration of performance characteristics.
 - · Where vibration or shock is directly transmitted to the body
 - Where the socket could come into contact with a solvent or alkaline agent
- Please insert PYDN terminal into the short bar insertion hole of G2RV-SR/G3RV-SR. If insert PYDN into the release hole or terminal (insertion) hole wrongly, PYDN may stuck and can not remove and it may cause result of damage on PYDN and G2RV-SR/G3RV-SR.








 Some arrow marks are added to the top of short bar as figures below. These arrow marks indicate the direction toward the relays mounted on the G2RV-SR/G3RV-SR series. When installing the short bar into G2RV-SR/G3RV-SR, short bar shall be installed as the arrow marks heading to the mounted relays.




- Do not use this device with the short bar inserted in the opposite direction. Otherwise, contact failure may result.
- When installing the short bar, insert it into the insertion hole in the correct orientation, and insert until all terminals are all the way in.



Completely inserted All terminals are inserted all the way in.



Incomplete insertion
All terminals are not inserted
all the way in.



Incorrect installation
Some terminals not inserted completely.



 To remove the short bar, insert a screwdirver beneath the rim on top of the short bar and lift up.

Start lifting up from either end, lift up all screwdriver in order, and then remove the short bar.







- If using a short bar, install the short bar before performing wiring work
- A push-in Plus terminal block type and a screw terminal type have different insertion positions, so a mixed installation using the same short bar is not possible.
- Do not insert short bar in the hole for wire or screw driver, it may
 cause the result of failure of pull out.
 - If insert short bar in the hole for wire or screw driver and try to pull out, it may cause damage for short bar or socket and failure in electric conductivity.
- Do not use this device with the short bar inserted in the opposite direction. Otherwise, contact failure may result.
- Please insert P2RVC terminal into the short bar insertion hole of G2RV-SR/G3RV-SR. If insert P2RVC into the release hole or terminal (insertion) hole wrongly, P2RVC may stuck and can not remove and it may cause result of damage on P2RVC and G2RV-SR/G3RV-SR.
 - Please turn off the power of input and output side and remove PLC interface unit when replacing mounting relays and SSRs for maintenance
- When replacing relays, there is a possibility the relay will pop out and fall. Take care to prevent the relay from falling during replacement.

 G2RV-ST/G3RV-ST accessories are not compatible and cannot be used.

Short Bars


- PYDN-6.2ST-200R
- PYDN-6.2ST-200S
- PYDN-6.2ST-200Y

PLC interface unit

- P2RVC-8ST-I-5-1
- P2RVC-8ST-I-5
- P2RVC-8ST-I-7-1
- P2RVC-8ST-O-5-1
- P2RVC-8ST-O-5
- P2RVC-8ST-O-7-1


Push-In Plus Terminal Block

1. Connecting Wires to the Push-In Plus Terminal Block Part Names of the Terminal Block



Connecting Wires with Ferrules and Solid Wires

Insert the solid wire or ferrule straight into the terminal block until the end strikes the terminal block.



 If a wire is difficult to connect because it is too thin, use a flat-blade screwdriver in the same way as when connecting stranded wire.


Connecting Stranded Wires

Use the following procedure to connect the wires to the terminal block.
(1) Hold a flat-blade screwdriver at an angle and insert it into the

release hole.
The angle should be between 10°and15°. If the flat-blade

screwdriver is inserted correctly, you will feel the spring in the release hole.

- (2) With the flat-blade screwdriver still inserted into the release hole, insert the wire into the terminal hole until it strikes the terminal block.
- (3) Remove the flat-blade screwdriver from the release hole.




Checking Connections

- After the insertion, pull gently on the wire to make sure that it will not come off and the wire is securely fastened to the terminal block.
- If you use a ferrule with a conductor length of 10 mm, part of the conductor may be visible after the ferrule is inserted into the terminal block, but the product insulation distance will still be satisfied.

2. Removing Wires from the Push-In Plus Terminal Block

Use the following procedure to remove wires from the terminal block. The same method is used to remove stranded wires, solid wires, and ferrules.

- (1) Hold a flat-blade screwdriver at an angle and insert it into the release hole.
- (2) With the flat-blade screwdriver still inserted into the release hole, remove the wire from the terminal insertion hole.
- (3) Remove the flat-blade screwdriver from the release hole.




3. Recommended ferrules and Crimp Tools Recommended ferrules

	Applicable wire		Stripping length	Recommended ferrules		
(mm²)	(AWG)	length (mm)	(mm) (Ferrules used)	Phoenix Contact product	Weidmuller product	Wago product
0.25	24	8	10	AI 0,25-8	H0.25/12	216-301
0.25	24	10	12	AI 0,25-10		
0.34	22	8	10	AI 0,34-8	H0.34/12	216-302
0.34	22	10	12	AI 0,34-10		
0.5	20	8	10	AI 0,5-8	H0.5/14	216-201
0.5	20	10	12	AI 0,5-10	H0.5/16	216-241
0.75	18	8	10	AI 0,75-8	H0.75/14	216-202
0.75	10	10	12	AI 0,75-10	H0.75/16	216-242
1/1.25	18/17	8	10	AI 1-8	H1.0/14	216-203
1/1.25	10/17	10	12	AI 1-10	H1.0/16	216-243
1.25/1.5	17/16	8	10	AI 1,5-8	H1.5/14	216-204
1.23/1.3	10		12	AI 1,5-10	H1.5/16	216-244
Recomm	mended	crimp tool		CRIMPFOX6 CRIMPFOX6T-F CRIMPFOX10S	PZ6 roto	Variocrimp4

Note: 1. Make sure that the outer diameter of the wire is smaller than the inner diameter of the insulating sleeve of the recommended ferrule.

2. Make sure that the ferrule processing dimensions conform to the following figure.




 If you use AWG24 to AWG22 (0.25 to 0.34 mm²) wires, UL and TÜV certification will not apply.

Recommended Flat-blade Screwdriver

Use a flat-blade screwdriver to connect and remove wires. Use the following flat-blade screwdriver.

The following table shows manufacturers and models as of 2015/ $\mbox{\rm Dec.}$



Model	Manufacturer
ESD 0,40×2,5	Wera
SZS 0,4×2,5 SZF 0-0,4×2,5 *	Phoenix Contact
0.4×2.5×75 302	Wiha
AEF.2,5×75	Facom
210-719	Wago
SDI 0.4×2.5×75	Weidmuller

^{*}OMRON's exclusive purchase model XW4Z-00B is available to order as SZF 0-0,4×2,5 (manufactured by Phoenix Contact).

Screw Terminal


Screw terminal

Wired type	Applicable wire size	Stripping length
Stranded wires, without ferrule	0.5 to 1.5 mm ²	8 mm
Stranded wires, with ferrule and plastic collar	0.5 to 1.5 mm ²	8 mm
Stranded wires with ferrule, without plastic collar	0.5 to 1.5 mm ²	8 mm
Single wire	0.5 to 1.5 mm ²	8 mm

Tightening Torque 0.4 N • m

Electric wiring

Use the electric wire of specified size as shown above. The length of the that is not covered is 8 mm.




Stripping length

<G2RV>

Operating latching lever (test switch)
When operating the latching lever for G2RV-SR701/501
series, use a 2.5 mm width flat-blade screwdriver.

· Applicable flat-blade screwdriver


Flat-blade screwdriver with parallel cutting edge: shaft diameter 2.5 mm (3.0 mm max.)



Driver with a thick shaft cannot be used.

- · Always turn OFF the power supply before operating latching lever.
- · Return to its original state after using the latching lever.
- · Do not use the latching lever as a switch.
- Operation durability of the latching lever is 100 times or more.
- Do not keep the latching lever ON for a long period of time (24 hours or more) in order to maintain the operation check function.

Method of operation of the latching lever (test switch)



Keep the protective cover open when using the latching lever. Move until the latching lever clicks to the ON position (ON state). After use latching lever, in order to prevent malfunction, return the switch to contact normal position (OFF state), and make sure the protective cover is firmly closed.

Using the latching lever

Example: check the operation of the relay and the sequence circuit

Input ratings


Smoothing capacitors are used in the internal circuits of AC/DC-type G2RV-SR devices. AC/DC-type G2RV-SR devices driven by the sensor may not operate normally due to the characteristics of the smoothing capacitor. When driving such devices by the sensor, use the DC specification settings.

<G3RV>

- Since the G3RV uses electronic components, do not allow it to fall, vibrate, or apply shock that exceeds the criteria. Doing so may result in failure, malfunction, or deterioration of performance.
- Tighten screw terminal for G3RV at torque 0.4 N \cdot m. It may cause short-circuit failure or burning.
- Please use the voltage and current suitable for the input and output terminal portion of G3RV. It may cause short-circuit failure or burning.


Mounting

<The SSR Mounting Pitch (Panel Mounting)>





* When five or more are installed, install with 10 mm space between each.


<Relationship of SSR and duct (duct depth)>



<Ventilation Outside the Control Panel>







- If the air inlet or air outlet has a filter, clean the filter regularly to prevent it from clogging to ensure an efficient flow of air.
- Do not place objects that may obstruct the proper ventilation for outside or inside the inlet or exhaust port, and in the outside vicinity.
- A heat exchanger, if used, should be located in front of the G3RV to ensure the efficiency of the heat exchanger.
- Please observe the ambient temperature of G3RV. The rated current of the G3RV is measured at an ambient temperature of 25°C.
- The G3RV uses a semiconductor in the output element.
 This causes the temperature inside the control panel to increase due to heating resulting from the flow of electrical current through the load. The G3RV reliability can be increased by adding a ventilation fan to the control panel to dispel this heat, thus lowering the ambient temperature of the G3RV.

(It suggests that life expectancy is doubled by each 10°C reduction in ambient temperature.)

EMI

The G3RV is a Class A product (for industrial environments). When used in a residential environment, it may cause radio interference. In such case, the user may be required to take appropriate measures.

G2RV-SR/G3RV-SR

For G2RV-SR/G3RV-SR Common Accessories (order separately)

Ordering Information

Short Bars

Appearance	Pitch	No. of poles	Colors	Model *	Minimum order (Quantity)	Maximum energizing current
	6.2 mm 4	2	Red (R), Blue (S),	PYDN-6.2-020□	10	32 A
		3		PYDN-6.2-030□		
		4		PYDN-6.2-040□		
		Yellow (Y)	PYDN-6.2-100□			
		20		PYDN-6.2-200□	=	

Note: Use for wiring to the adjacent socket.

*Replace the box (\Box) in the model number with the code for the covering color. \Box color selection: R = red, S = blue, Y = yellow

Label

Appearance	Model	Minimum order (Sheet) (Pieces per sheet)
	XW5Z-P2.5LB1 *	5
	XW5Z-P2.5LB2	(1 sheet/72 pieces)

* Available following June 2017 production.

Separate Plate

Appearance	Model
	XW5Z-EP12

PLC interface unit

Appearance	I/O classification	Connection method	Common process	Applicable Models *	Model
	For input	Push-In	PNP	- G2RV-SR500-AP	P2RVC-8-I-5-1
-			NPN		P2RVC-8-I-5
		Screw	PNP	G2RV-SR700-AP	P2RVC-8-I-7-1
	For output	Push-In	PNP	G2RV-SR500 G2RV-SR501 G3RV-SR500	P2RVC-8-O-5-1
			NPN		P2RVC-8-O-5
		Screw	PNP	G2RV-SR700 G2RV-SR701 G3RV-SR700	P2RVC-8-0-7-1

^{*} Please make sure applicable models, P2RVC can not be used other combination than the above table.

Parts for DIN Track Mounting

Appearance	Туре		Model	Minimum order (Quantity)	
	DIN Tracks	1 m	PFP-100N	1	
		0.5 m	PFP-50N		
5	End Plate *		PFP-M	40	
	Spacer		PFP-S	10	

***** When mounting DIN Track, please use End Plate (PFP-M). Refer to your OMRON website for details on PFP-□.

Applicable Cables

Name		Appearance	Cable length L (mm)	Connecting Cables	Applicable Connectors
	8 I/O points	End A End B	1,000	P2RV-A100C	
Cables with Loose		Device PLC interface end unit end	2,000	P2RV-A200C	Wasing daying
Wires P2RV-A□C			3,000	P2RV-A300C	Various devices
		 	5,000	P2RV-A500C	
			1,000	P2RV-4-100C	
OMRON PLC Connecting Cables with	32 output points		2,000	P2RV-4-200C	PLC I/O Units with MIL connectors (1:4)
Connectors (1:4) P2RV-4-□C			3,000	P2RV-4-300C	CJ1W-OD232/OD262, etc.
		300 →	5,000	P2RV-4-500C	
	32 input points		1,000	P2RV-4-100IMC	PLC I/O Units with MIL connectors (1:4) CJ1W-ID232/ID262, etc. *1
OMRON PLC Connecting Cables with			2,000	P2RV-4-200IMC	
Caples with Connectors (1:4) P2RV-4-□IMC			3,000	P2RV-4-300IMC	
		L→L→ 300 →	5,000	P2RV-4-500IMC	
	32 input points		1,000	P2RV-4-100IFC	
OMRON PLC Connecting Cables with Connectors (1:4) P2RV-4-□IFC		ut 300	2,000	P2RV-4-200IFC	PLC I/O Units with Fujitsu/Otax connectors (1:4)
			3,000	P2RV-4-300IFC	CJ1W-ID231/ID261, etc. *2
			5,000	P2RV-4-500IFC	
OMRON PLC	8 output	Removable terminal block	500	P2RV-A050C-OMR NX	PLC I/O Units with screw-less clamp
Connecting Cables with	points		1,000	P2RV-A100C-OMR NX	terminal block (1:1)
Connectors (1:1)	8 input points		500	P2RV-A050IC-OMR NX	For inputs: NX-ID4442 For outputs: NX-OD4256
P2RV-A□C-OMR NX		 L 	1,000	P2RV-A100IC-OMR NX	,

^{*1.} Use the P2RVC-8-I--1(PNP) as the PLC interface unit when connecting to the CJ1W-ID232/ID262 (or a unit with an equivalent terminal arrangement).

*2. Use the P2RVC-8-I-□-1(PNP) as the PLC interface unit when connecting to the CJ1W-ID231/ID261 (or a unit with an equivalent terminal

arrangement).

Name		Appearance	Cable length L (mm)	Connecting Cables	Applicable Connectors
		5 14	500	P2RV-050C-SCH-A	
	00 in	End A End B Device PLC interface	1,000	P2RV-100C-SCH-A	
	32 input points	end unit end	2,000	P2RV-200C-SCH-A	
			3,000	P2RV-300C-SCH-A	Schneider Electric PLCs with 32-point connectors (1:4) For inputs: 140 DDI 353 00 For outputs: 140 DDO 353 00
			5,000	P2RV-500C-SCH-A	
			500	P2RV-050C-SCH-B	
	20 output		1,000	P2RV-100C-SCH-B	
	32 output points		2,000	P2RV-200C-SCH-B	
Schneider Electric		L → 300 →	3,000	P2RV-300C-SCH-B	
PLC Connecting		14 L -> 4 300 ->	5,000	P2RV-500C-SCH-B	
Cables P2RV-□C-SCH-□			500	P2RV-050C-SCH-C	
	16 input	Д.	1,000	P2RV-100C-SCH-C	
	points		2,000	P2RV-200C-SCH-C	
			3,000	P2RV-300C-SCH-C	Schneider Electric PLCs with
			5,000	P2RV-500C-SCH-C	16-point connectors (1:2)
			500	P2RV-050C-SCH-D	For inputs: BMX DDI 1602 For outputs: BMX DDO 1602
	40 1 1		1,000	P2RV-100C-SCH-D	1 of outputs. BMX BBO 1002
	16 output points		2,000	P2RV-200C-SCH-D	
	ľ	 	3,000	P2RV-300C-SCH-D	
			5,000	P2RV-500C-SCH-D	
			500	P2RV-050C-SIM-A	
			1,000	P2RV-100C-SIM-A	
	32 input points		2,000	P2RV-200C-SIM-A	
	poto		3,000	P2RV-300C-SIM-A	Siemens PLCs with 32-point connectors (1:4)
			5,000	P2RV-500C-SIM-A	
			500	P2RV-050C-SIM-B	For inputs: 6ES7 321-1BL00-0AA0
			1,000	P2RV-100C-SIM-B	For outputs: 6ES7 322-1BL00-0AA0
	32 output points	- L - 300 -	2,000	P2RV-200C-SIM-B	
	pointo		3,000	P2RV-300C-SIM-B	
			5,000	P2RV-500C-SIM-B	
			500	P2RV-050C-SIM-C	
)' DI O			1,000	P2RV-100C-SIM-C	o: Dio :
Siemens PLC Connecting Cables P2RV-□C-SIM-□	16 input points		2,000	P2RV-200C-SIM-C	Siemens PLCs with 16-point connectors (1:2) For inputs: 6ES7 321-1BH02-0AA0
P2RV-UC-SIM-U			3,000	P2RV-300C-SIM-C	
		L→L→ 300 →	5,000	P2RV-500C-SIM-C	
			500	P2RV-050C-SIM-D	
	20: 1		1,000	P2RV-100C-SIM-D	
	32 input points		2,000	P2RV-200C-SIM-D	
			3,000	P2RV-300C-SIM-D	Siemens PLCs with
	32 output points		5,000	P2RV-500C-SIM-D	32-point connectors (1:4)
		-L - 300 -	500	P2RV-050C-SIM-E	For inputs: 6ES7 421-1BL-0AA0
			1,000	P2RV-100C-SIM-E	For outputs: 6ES7 422-1BL-0AA0
			2,000	P2RV-200C-SIM-E	1
			3,000	P2RV-300C-SIM-E	1
			5,000	P2RV-500C-SIM-E	1


PLC interface unit

Ratings / characteristices


Rated voltage		30 VAC/DC		
Rated current		0.5 A/poles, 2 A/unit		
Ambient operating temperature		–40 to 55°C		
Vibration resistance	Destruction	10 to 55 to 10 Hz, single amplitude 0.75 mm (double amplitude 1.5 mm)		
VIDIALIOII TESISLATICE	Malfunction	10 to 55 to 10 Hz, single amplitude 0.75 mm (double amplitude 1.5 mm)		
Shock resistance	Destruction	300 m/s ²		
SHOCK resistance	Malfunction	100 m/s ²		

Electrical schematic


Input P2RVC-8-I-□-1 (PNP)




P2RVC-8-I-5 (NPN)



Output P2RVC-8-O-□-1 (PNP)




P2RVC-8-O-5 (NPN)





PLC interface unit

Push-IN P2RVC-8-I-5(-1) P2RVC-8-O-5(-1)












(unit: mm)

Screw P2RVC-8-I-7-1 P2RVC-8-O-7-1










(Except for PLC interface unit) Common Accessories (order separately)

Dimensions (unit: mm)

Short Bars

PYDN-6.2-□□ (6.2 mm)




Pitch	No. of poles	L (Length)	Colors	Model *	Maximum carry current
	2	12.4		PYDN-6.2-020□	
6.2 mm	3	18.6	Red (R) Blue (S) Yellow (Y)	PYDN-6.2-030□	32 A
	4	24.8		PYDN-6.2-040□	
	10	62		PYDN-6.2-100□	
	20	124		PYDN-6.2-200□	

Note: Use the Short Bars for crossover wiring within one Socket or between Sockets. ★ Replace the box (□) in the model number with the code for the covering color.

Model	Number of arrows	Top View
PYDN-6.2-020□	1	
PYDN-6.2-030□	2	
PYDN-6.2-040□	2	
PYDN-6.2-100□	6	
PYDN-6.2-200□	14	

Separate Plate XW5Z-EP12



Parts for DIN Track Mounting

Refer to your OMRON website for details on the PFP-.


G2RV-SR/G3RV-SR

Safety Precautions

Precautions for Correct Use


When mounting a short bar

 Intermediate pins can be bent by a tool or by hand and cut off for use.




The short bar can be cut to as many poles as needed. Insert the
tool from the plastic part side, and cut along the groove in the
plastic part between the terminals. When cutting, take care not to
break or deform the terminals.

However, because the metal on the cut surface will be exposed, insulation countermeasures between adjacent products must be ensured. Such countermeasures include widening the intervals between products or using XW5Z-EP12 separate plates (order separately).




 When cutting the short bar or its pins, do not touch the conductive part. If the conductive part is deformed, contact failure may result.



Mounting a separate plate

 Use a flat-blade screwdriver to tighten the center top screw and secure the plate. Loosen the screw to remove the plate from the DIN rail.



Terms and Conditions Agreement

Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

Warranties.

- (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.
- (b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See http://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions.

Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

Note: Do not use this document to operate the Unit.

OMRON Corporation Industrial Automation Company

Kyoto, JAPAN Contact : www.ia.omron.com

Regional Headquarters

OMRON EUROPE B.V.

Wegalaan 67-69, 2132 JD Hoofddorp The Netherlands Tel: (31) 2356-81-300 Fax: (31) 2356-81-388

OMRON ASIA PACIFIC PTE. LTD.

438B Alexandra Road, #08-01/02 Alexandra Technopark, Singapore 119968 Tel: (65) 6835-3011 Fax: (65) 6835-3011

OMRON ELECTRONICS LLC

2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900 Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD.

Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Tel: (86) 21-6023-0333 Fax: (86) 21-5037-2388

Authorized Distributor:

©OMRON Corporation 2016-2024 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

CSM_6_21

Cat. No. J214-E1-14 0124 (0316)